

GMR KAMALANGA ENERGY LIMITED
3X350 MW



CALIBRATION CERTIFICATE FOR PRESSURE TRANSMITTER

Page No : 1 of 1

Certificate No - CC/GKEL/25-07/041

Format No - GKEL/C&I/R/CRSE-05_A

Tag No : 00GCB23CF001

Calibration Date : 24/07/2025

Description : Flow of #4 Activated Carbon FilterInlet

Valid Upto : 23/07/2026

Range : 0-40 Kpa

WI No : GKEL/08/C&I/301/,320/327/328/339

Environment Cond. : Ok

Least Count : 0.01 Kpa

Master / Reference used for Calibration

Reference Standard			Traceability	
Name	Model	Range	Certificate No.	Calibration Valid
Digital Multimeter	17B		EMC2023-KOL-00071094	12/12/2025
Digital pressure gauge	DPI-610	-1 - 10 bar	EMC2023-KOL-00069873	12/12/2025

TEST RESULT

Val1	Sr. No.	INPUT APPLIED THROUGH THE MASTER EQUIPMENT		RESULT OBSERVED IN THE EQUIPMENT UNDER CALIBRATION		ERROR OF THE EQUIPMENT UNDER CALIBRATION		Remark
		APPLIED VALUE	*VALUE AFTER COMP.	RISING	FALLING	RISING	FALLING	
RESULTS BEFORE CALIBRATION	1	0	0	0	0	0.00	0.00	
	2	10	10	10.01	10.01	0.02	0.02	
	3	20	20	20	20	0.00	0.00	
	4	30	30	30.04	30.04	0.10	0.10	
	5	40	40	40.04	40.04	0.10	0.10	
RESULTS AFTER CALIBRATION	1	0	0	0	0	0.00	0.00	
	2	10	10	10.01	10.01	0.02	0.02	
	3	20	20	20	20	0.00	0.00	
	4	30	30	30.04	30.04	0.10	0.10	
	5	40	40	40.04	40.04	0.10	0.10	

SUVENDU GIRI
MANAGER
CALIBRATED / REVIEWED BY



SUVENDU GIRI
MANAGER
AUTHORIZED SIGNATORY